

C/20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 428

Dated: 26/7/2022

To,

The Principal,  
M. C. Primary Co-ed School,  
Sector-9, Rohini,  
Delhi-110085,

**Sub:** Issue of FSC in r/o M. C. Primary Co-ed School, Sector-9, Rohini, Delhi-110085.


Sir,

Kindly reference to online e-mail dated 21.05.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **01.07.2022**, in presence of **Smt. Rajesh Kumari (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Hose reel nozzle is not provided.
2. Terrace Fire pump with capacity 450 LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours faithfully

  
(Dhrampal Bhardwaj)  
Dy. Chief Fire Officer  
Tel;-01123414250

o/c  
