

101
c/193Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/WZ/2022/ 488

Dated: 26/7/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adddlp.lic-dl@nic.in

Subject: - Inspection report in r/o Miss Nora (A unit of Rcube Hospitality LLP) Located at, Shop No. CS 103 and 104, First Floor, Rcube Monad, Rajouri Garden, New Delhi-110027.

Sir,


Please refer to your online application no.: - 2022060612136 dated 06/06/2022 on the subject cited above. In this connection it is to inform you that the premises was inspected by officer concerned of this department on 04/07/2022 in the presence of Sh. Anup (Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, It has been observed that the said restaurant is running at 1st floor in a building comprised of 03 Basement + Ground + 4 Upper floors was issued FSC vide letter No. F6/DFS/MS/WZ/2019/2254 dated 03/12/2019. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Terrace Pump & Exit signage and etc. are provided. However the following shortcomings were observed.

1. First-Aid Hose Reels Found Leakage.
2. MOEFA is provided but not functional.
3. Exit Signage are found removed.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. M/s. Miss Nora (A unit of Rcube Hospitality LLP) Located at, Shop No. CS 103 and 104, First Floor, Rcube Monad, Rajouri Garden, New Delhi-110027.
2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.
(dhowest_zone@gmail.com)

o/c
DHP
26/7/2022

ADD (MN)