

5-235 1/18
9/20



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2022 /436

Dated: 27/7/2022

To

The Principal,
Delhi United Christian Sen. Sec. School,
17, Raj Niwas Marg, Delhi- 110054.

Sub:- Regarding issuance of Fire Safety Certificate in r/o **The Delhi United Christian Senior Sec. School** located at **17, Raj Niwas Marg, Delhi.**


Sir,

This has reference to letter no. nil dated 20.06.2022 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 14.07.2022 in the presence of Mrs. Monika Alexander (Principal). During the inspection, following shortcomings were observed:-

1. Fire extinguishers found non functional.
2. Public address system not provided.
3. Exit signages are not provided.
4. Domestic LPG cylinder cannot be used in science lab for any purpose.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(S. K. Dua)

Dy. Chief Fire Officer o/c
Delhi Fire Service
8/27/22

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.