

c-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Restaurant/WZ/2022/490

Dated: 26/7/2022

To,

Mr. Reshma Sharma,
House No.BH0-684, East Shalimar Bagh,
Delhi-110088.

Sub: Issue of FSC in r/o M/s RSK Hospitality, The Sial Kitchen, DDA Market, R-1, CSC-5, Sector-14, Rohini, Delhi-110088.

Sir,

This is reference to online application no. No2022052310952 dated 26.05.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **06.07.2022** in presence of **Sh. Ram Swaroop Sharma (Owner)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of additional door is 1.1m each against the required width of door of 1.5 mtr.
2. Fire check door is not provided in kitchen.
3. Hose reel provided but not functional.
4. MOEFA is not provided.
5. Terrace fire pump is not connected with water tank & no electricity connection is provided.
6. 5000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs.
7. Down comer provided but not functional.
8. Building plans provided are not matching with restaurant.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Anil Garg)
DIRECTOR

Ph; 011-23414000

OTC
A/L