GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE **NEW DELHI**

No. F6/DFS/MS/GH/WZ/2022/ 603

Dated: 22/ 07 /2022

To.

Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. E-Mail - Addcp.lic@delhipolice.gov.in.

Subject: - Regarding issuance of NOC from Fire Safety point of view in r/o M/s. West Delhi Inn 33-33 A, Rama Road, New Delhi- 110015.

Sir.

116

Please refer to your online application no.:-2022051810626 dated 18/05/2022 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 29/06/2022 in the presence of Sh. Babar Ali (Care Taker) to check the shortcomings already issued by this department vide letter No. F6/DFS/MS/MN/GH/2021/718 dated 18/10/2021.

The Status of shortcomings is as under:-

S.N.	Shortcomings	Status
1.	One Staircase of width 90 cm provided against requirement of	Not Rectified
	two staircases having width 1.5m each.	
2.	Width of corridor 93 cm provided against 1.5 m required.	Not Rectified
3.	Width of the doors is 01 mts provided against 1.5 mts required.	Not Rectified
4.	Smoke management system is not provided in the basement & upper floor.	Not Rectified
5.	Carbon Monoxide detectors are not provided.	Not Rectified

In view of above Shortcomings, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

Director Delhi fire service

Copy to: -

- 1. The Owner/Occupier of M/s The Rohit Chadha, West Delhi Inn 33-33 A, Rama Road, New Delhi 110015.
- 2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027. (dhowest zone@gmail.com)

517/2022

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

No.F6/DFS/MS/MN/GH/2021/718

Dated: 18 / 10 /2021

05

To,

The Rohit Chadha, West Delhi Inn 33-33 A, Rama Road New Delhi 110015.

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s west Delhi Inn 33-33 A, Rama Road, New Delhi- 110015.

Sir,

Please refer to your online application no. 2021090319986 dated 03/09/2021 on the subject mentioned above. In this connection, it is to inform you that the premise was inspected by the officers of this department on 28/09/2021 to check the fire safety arrangements.

During inspection, It was observed that the building is comprised of Basement, Ground plus 03 Upper Floors served by single staircase having width 0.9 mt., Guest House is running Ground Floor, first Floor, Second Floor & Third Floor. Fire safety arrangements such as Fire Extinguishers, Exit Signage etc. found provided. However, following shortcomings were observed:-

- 1. One Staircase of width 90 cm provided against requirement of two staircases having width 1.5m each.
- 2. Width of corridor 93 cm provided against 1.5 m required.
- 3. Width of the doors is 01 mts provided against 1.5 mts required.
- 4. Smoke management system is not provided in the basement & upper floor.
- 5. Carbon Monoxide detectors are not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

Director

Delhi Fire Service

110/02/

Copy to: -

1. M/s The Rohit Chadha, West Delhi Inn 33-33 A, Rama Road New Delhi 110015.

2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.