

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2022/ 497

Dated: 27/7/2022

To

The Dy. Health Officer, SDMC
Public Health Officer,
Aurobindo Marg, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o /s /s 3 Idiots (A Unit of 3 Idiots Bar Pvt Ltd., Shop No. HS1, First & Second Floor, Kailash Colony Market, New Delhi 110048


Sir,

This has reference to your **MHA Portal ID No. 202206313388** dated **23/06/2022** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.07.2022 in the presence of Mr. Rachit Nayyar to verify the fire safety measures installed in the building and observed that restaurant running at First and Second floor of the building comprised of Basement, ground plus two upper floors. During inspection, following points were observed:

- 1 Smoke ventilation system provided but not functional at upper floors.
- 2 Hose reel hose provided but not functional.
- 3 The Internal Hydrant provided but not functional.
- 4 Terrace level Fire Pump capacity of 450 LPM provided but not functional.
- 5 Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.