

112

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 443

Dated: 01/08/2022

To,

The Principal,  
Aurobindo Public Secondary School,  
Budh Vihar,  
Delhi-86,

**Sub:** Issue of FSC in r/o Aurobindo Public Secondary School, Budh Vihar, Delhi-86.

Sir,

This is reference to your letter no. nil dated nil received through outdoor dairy no. 2830 dated 29.06.2022 of this department, on the subject cited above. The premise was inspected by the concern nominated authority of this department on **21.07.2022**, in presence of **Mr. Jai Prakash** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 450 LPM provided but not functional.
2. Over Head fire water captive tank capacity found reduced to 6600 against the required capacity of 10,000 ltrs.
3. Water supply connection to terrace tank not connected.
4. One more block of ground + 01 upper floor found available in school premises.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htp://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htp://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours faithfully

  
**(Dhrampal Bhardwaj)**  
**Dy. Chief Fire Officer**  
**Tel:-01123414250**

o/c  
dy