



No.F6/DFS/MS/School/SZ/2022/ 446

Dated: 01/08/2022

To

The Principal,
Bal Niketan Public School,
A-59, Sangam Vihar, New Delhi-62 (ID 1923270).

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Bal Niketan Public School located at A-59, Sangam Vihar, New Delhi-62 (ID 1923270).**

Sir,

With reference to your letter no. BNPS/DP/2022/197 dated 14.02.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 20.07.2022 in the presence of Mr. Mukesh Singhal (Accountant) and it was observed that the school building is comprised of 02 blocks- (Basement (sealed) + Ground + 3 upper floors & Ground + 3 upper floors). During the inspection following shortcomings were observed:-

1. Hose reels found non functional.
2. Fire pump found removed.
3. Exit signages are not adequate.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

01/08/2022

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST, South Block-C, Defence Colony,
New Delhi-24.