

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/GH/2022/SZ/ 621

Dated: 28/07/2022

To,

The Manager,
Hotel Heven, BE-140, Street No.-3,
Hari Nagar New Delhi-110064.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Hotel Heven, BE-140, Street No.-3, Hari Nagar New Delhi-110064.

Sir,

Please refer to your letter ID No. 2022062313384 dated 23/06/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Manpreet Singh (Manager) was present and it was observed that the building is comprised of basement (closed) ground plus three upper floors and have following shortcomings:-

1. Both staircases shall be provided 1.5 m wide.
2. First aid hose reel not provided.
3. MOEFA & P A System not provided.
4. Down comer system not provided.
5. Fire pump having 450 LPM not provided at terrace.
6. Overhead water tank capacity of 10,000 ltrs not provided.
7. Exit signage's are not provided.
8. Standby power supply not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be taking suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)

Director
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police, 1st Floor, Licensing Unit, Police Station, Defence Colony,
New Delhi-110064.