



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

9/61  
75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/GH/SZ/2022 /617

Dated: 27/7/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Sub: Regarding Validation of Fire Safety Certificate in r/o **M/s Kaisons Inn Guest House located at Plot no. 52, Pocket -I, Jasola New Delhi-25.**

Sir,

With reference to the online application no. 2022063013795 & email dated 11.07.2022 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on. 22.07.2022 in the presence of Mr. Rishi Jain, Owner and following shortcomings were observed.

1. Hose reels found non functional.
2. Fire pumps found non functional.
3. Poly vinyl sheet at terrace should be removed.
4. Kitchen found operational at still floor. The use of stilt floor is not as per the approved building plan.

In view of above shortcomings, the application for validation for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Sunil Chawdhary)

Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Licensee, M/s Kaisons Inn Guest House located at Plot no. 52, Pocket -I, Jasola New Delhi-25.

26/7