

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2022/432

Dated: 26/07/2022

To

The Principal,
Sarvodaya Co-ed Sr. Sec. School,
Moti Bagh-II, Nanak Pura,
New Delhi 110021

Sub: Regarding renewal of FSC in r/o Sarvodaya Co-ed Sr. Sec. School, Moti Bagh-II, Nanak Pura, New Delhi 110021.

Sir,

This has reference with letter No SV/CO.ED/MB-II/NP/2022-23/151 dated. 04-07-2022 on the subject cited above. In this connection, the school premises have been inspected by officer concerned of this department on 14/07/2022. During the inspection, it was observed that there are material changes in the building as additions/alterations have been made in the building/premise affecting the fire prevention and fire safety measures including the means of escape. The school building now comprised of old block: each ground plus one upper floor (02 no's) New block: ground plus two upper floors the new building is connected with old blocks at each floor end through corridor up to first floor. The shortcomings observed are as below.

1. Newly constructed block having ground plus two upper floors served with two staircases only. Which do not meet the required travel distance. Additional 02 no's staircase having width of 1.50 not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully/

(ATUL GARG)
DIRECTOR

Copy to:-

1. The Director of Education, Govt. of NCT Of Delhi, Old Secretariat, New Delhi 110054