

936

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001**

No: F.6/DFS/MS/School/2022/SZ/ 434

Dated: 27/7/2022

To,

The Principal,  
Shanti Gyan International School,  
Goyla, Najafgarh, New Delhi-71

**Sub:** - Regarding issuance of Fire Safety Certificate in r/o. Shanti Gyan International School, Goyla, Najafgarh, New Delhi-71


Sir,

This has reference to your Letter No. SGIS/22-23/07/15 dated 05/07/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 08/07/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Mr. Baldev Raj Khurana was present and it was observed that the school building is comprised of ground plus three upper floors and have following shortcomings.

1. Hose reels are provided but not functional.
2. Fire pump having 450 lpm provided but not functional.
3. Exits signages are provided but not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

  
(Sunil chawdhary)

**Dy. Chief Fire Officer**  
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.(with a request to take further action as school does not have fire NOC)