

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No F6/DFS/MS/School/ND/2022/ 1915

Dated - 29 07 2022

To

The Executive Engineers(Bldg.),
East Delhi Municipal Corporation,
Delhi.

**Sub: Regarding issuance of FSC in r/o Tamil Education Sr. Sec School (DTEA) located at
Mayur Vihar Phase-III, Delhi-92.**

Sir,

This has reference to joint inspection online I.D-10105072 dated 20/07/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 26/07/2022 in the presence of Mr. K.K Gupta, J.E.(B), Mr. S.D. Tomar EE(Bldg)/Shah(S), Mr. Arvind (Architect), Mr. R. Raju & Ms. Shabana from school site and observed that widening of access road work is in progress and pump were not installed yet.

Hence, the Fire Safety Certificate cannot be considered at this stage. The management is requested to rectify the above shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
of-
nw

Copy to:-

The Principal,
Tamil Education Sr. Sec School,
Mayur Vihar Phase-III, Delhi-92.