



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

C-67

No. F6/DFS/MS/WZ/2022/BNOT/136

Dated: 02/08/2022

To,
The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlep.lic-dl@nic.in

Sub: - Inspection report in r/o M/s. Royal Lush (A unit of Royal Lush Private Limited) located at C- 91/10, Ashok Vihar, Block- C, Wazirpur Industrial Area, Delhi- 110052.

Sir,

A surprise inspection has been carried out by the Nominated Authority of Delhi Fire Service after serving 03 hours notice as per section 33(1) of Delhi Fire Service Act 2007 on 03/06/2022 to check the functionability of existing fire safety arrangements. After inspection, shortcomings were issued by this department vide letter No: DFS/DO(West)/2022/Directions/141 dated 03/06/2022.


The building was re-inspected by the Nominated Authority on 25.07.2022 to check the compliance of shortcomings already issued by this department vide letter dated 03.06.2022 and observed that the management has not rectified all the shortcomings.

In view of the above, the fire safety certificate was suspended vide this department letter No. DFS/DO(West)/2022/Directions/141 dated 03/06/2022 cannot be revoked. The management may be advised to comply all the shortcomings under intimation to this department and not to use the banquet hall in the interest of occupant's safety till the repair of the fire safety arrangements.


Anil Garg
Director
Delhi Fire Service

Copy To:-

1. The owner/occupier, M/s. Royal Lush Banquet Hall, C- 91/10, Ashok Vihar, Block- C, Wazirpur Industrial Area, Delhi- 110052.
2. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.

9c  01/8/2022

C-62

FORM 'P': FORM OF NOTICE
[See section 34 (1)/43(2) of the Act]
[See sub-rule (6) of rule 41]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-1100 01

No. DFS/DO(West)/2022/Directions/141


Dated: 03/06/2022

NOTICE FOR CARRYING OUT THE DIRECTIONS OF THE NOMINATED AUTHORITY

We, M.K. Chattopadhyay, DO (West), the Nominated Authority appointed under the Act, on the basis of inspection conducted by us on 03-06-2022, do hereby call upon you to undertake the following Fire Prevention and Fire Safety measures in building/premises- M/s. Royal Lush Banquet, C-91/10, Wazirpur Industrial Area, Delhi- 110052: -

1. Pumps connected with underground & overhead tank found non-functional.
2. Tanks are running without water.
3. Fire Check doors removed, LPG bank shall be removed from staircase.
4. Automatic detection, MOEFA found non-functional.
5. Sprinkler system, hydrant system & hose reel hose found non-functional.
6. Exit signages removed. Ventilation system removed.
7. Alternate staircase running to the terrace is closed.

Above action should be completed latest by 18.06.2022. Till such time, fire safety certificate issued by this department vide letter No. F.6/DFS/MS/WZ/2020/BNQT/121 dated 28.02.2020, is suspended and you will not use the Banquet Hall in the interest of occupant's safety till the repair of the fire safety arrangements.


03/06/2022
(M.K. Chattopadhyay)
Nominated Authority
Delhi Fire Service

To

1. The Occupier/Owner, M/s. Royal Lush Banquet, C-91/10, Block-C, Wazirpur Industrial Area, Delhi- 110052.
2. The Dy. Health Officer, Keshapuram Zone, Public Health Department, North DMC, A-1, Block, Keshavpuram, New Delhi.