

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Institute/2022/SZ/ 37

Dated: 28/7/2022

To,

Mr. Vijay Pal Singh (Admin. Officer)  
Lingaya's Lalita Devi Institute of Management & Science  
Mandi Road, Mandi, New Delhi 110047

Sub: Regarding issuance of Fire Safety Certificate in r/o Lingaya's Lalita Devi Institute of management & Science (Main Building) Mandi Road, Mandi, New Delhi 110047.

Sir,

This was reference to your Gmail of dated 20/06/2022 on the subject cited above. It is inform you that the premise was inspected by the concern nominated authority of this department on 11/07/2022 to ascertain the availability and operability of the fire prevention and fire safety measures. During the course of inspection, the following shortcoming observed were noticed:-

1. The entrance main gate width is less than of 4.5mtr.
2. Fire fighting pumps are not on auto mode.
3. Sprinkler system in basement is not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to:

1. The Asstt. Engineer (Bldg) SDMC, South Zone, Green Park Zone, New Delhi 110016