

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

NO.F6/DFS/MS/2022/WZ/ Coelege 39

Date: 02 8 2022

Τo,

Sh. J.S. Chauhan, Asstt. Director(Estate), National Institute of Labour Economics Research and Development, Plot No. 25, Sec. A-7, Institutional Area, Narela, Delhi-110040.

Sub: Regarding Grant of Fire Safety Certificate in respect of National Institute Of Labour Economics Research and Develoment, Plot No. 25, Sec-A-7, Institutional Area, Narela Delhi-40.

Sir,

This has the reference to your letter No. NILERD/Estate/2018-19/Equip.(Elect.)received via outdoor diary no. 2235 of this department dated 02/06/2022 on the subject sited above, it is submitted that the aforesaid building was visited by officers concerned of this department on 19.07.2022 in presence of Sh. J.S Chauhan (Asstt. Director, Estate) and Sh. S.K Tanwar (A.E. Electrical). Your request for issuance of FSC is rejected as following shortcoming/observations were observed at the time of inspection.

Academic Block:

- 1. First aid hose reel provided but not functional.
- 2. Exit signage found missing at some strategic locations.

Seminar Block:

- 1. Smoke management system not provided in auditorium hall.
- 2. Beam detectors are not installed at suitable locations.
- 3. Seating arrangement is not as per DSA/NBC as there are more than 14 seats are in a row.
- 4. Fist aid hose reel not provided near auditorium hall.
- 5. Exit signage not provided.

The details of building blocks which are not in purview of this department are as under:

S. No.	Name of the block Library/Canteen	Building Comprised	Max. Height of the building in (m) 11.85 m
1.		Ground+2 upper floors	
2.	Admin./Finance Block	Ground+1 st Floor	11.85 m
3.	International Hostel	Ground+3 upper floors	12.65 m

1-23

4.	Management/DG Office	Ground +1 st floor	7.65 m
5.	Residential Quarters	Ground+02	9.75 m
	Type I,II,III & IV and	and	
	Director Bunglow, Type V & VI		
	Quarters	Duplex (Gr.+1 st floor)	6.63 m
6.	Guest House	Ground+2 upper floors	9.60 m

You are requested to apply again after compliance of the above mentioned shortcomings for further consideration in this matter.

Yours Faithfully

22

Delhi Fire Service

Copy to:

1. The Assistant Engineer (E), Air-Conditioning Division-III, C.P.W.D., Block-III, Level-7, R.K. Puram, New Delhi.