

C5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2022/94/630

Dated: 02/08/2022

To

The Manager,
Aman Imperial Guest house
3736-373, Dariba Pan
Pahar Ganj, New Delhi.

Subject:- **Regarding issuance of FSC in r/o M/s Aman Imperial Guest house located at 3736-373, Dariba Pan Pahar Ganj, New Delhi. ID No. 2022062813671 dated 07.07.22**

Sir,

This has a reference to online application ID No. 2022062813671 dated 07.07.22 on the subject cited above. In this connection, it is to inform you that the site was visited on dated 20.07.22 by the officers concerned of this department and following shortcomings are observed.

1. Fire check door is not provided at basement.
2. Hose reel provided but found nonfunctional.
3. Smoke management system not provided in basement.
4. Pump found non functional
5. Lift signages not provided.
6. Reception & store is shown at the stilt floor on the plans submitted through portal whereas stilt floor shall be used for parking only.
7. Total no. of floors & no. of specific floor on which establish is situated is not mentioned correctly in the application form.

In view of above, the Fire safety certificate cannot be issued. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,


(A. G. G.)
DIRECTOR
Delhi Fire Officer

Copy to :-

The Jt. Commissioner of police (Lic) 1st Floor, Defense colony police station, New Delhi