



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

o.F6/DFS/MS/School/SZ/2022/ 448

Dated: 4/8/22

To

The Principal,  
Jai Hind Public School,  
E-127, Aali Vihar, New Delhi-76.

**Sub:-** Regarding renewal of Fire Safety Certificate in respect of **Jai Hind Public School located at E-127, Aali Vihar, New Delhi-76.**

Sir,

With reference to your letter no. nil dated 23.05.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 21.07.2022 in the presence of Sh. Rakesh Kumar (Owner) and it was observed that the building which was earlier comprised of ground + 2 upper floor is now comprised of ground + 3 upper floors. 3<sup>rd</sup> floor has been newly added to the building. Hence is a case addition/alteration. The fire and life safety requirements are therefore applicable as prescribed in Unified Building Byelaws 2016 and National Building Code 2016 as per which following shortcomings were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters
2. Main and alternate staircase of 1.50 meters width each shall be provided in the building.
3. Hose reel not provided.
4. Fire pump having capacity 450 LPM & head 40 mtrs. not provided .
5. Overhand tank capacity 10,000 ltrs not provided for fire fighting.
6. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director

Delhi Fire Service

o/c 4/8/22

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.