



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2022/ 449

Dated: 4/8/22

To

The Principal,
Modern Gyan Deep Public School,
B-280, Tigri Extn., New Delhi-62.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s **Modern Gyan Deep Public School located at B-280, Tigri Extn., New Delhi-62.**

Sir,

With reference to your letter no. GD 446 dated 28.06.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 20.07.2022 in the presence of Sh. R. K. Gupta (Manager) and it was observed that the building which was earlier comprised of ground floor only is now comprised of 2 block (Ground + 2 upper floors each). 1st & 2nd floor in block -1 & another block is Ground + 2 upper floors has been newly added to the building. Hence is a case addition/alteration. The fire and life safety requirements are therefore applicable as prescribed in Unified Building Byelaws 2016 and National Building Code 2016 as per which following shortcomings were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters
2. Main and alternate staircase of 1.50 meters width each shall be provided in the each block.
3. 06 nos. fire extinguishers provided against the requirement of 18 nos. fire extinguishers.
4. Hose reel not provided in each block.
5. Fire pump having capacity 450 LPM & head 40 mtrs. not provided in each block.
6. Overhand tank capacity 10,000 ltrs not provided in each block for fire fighting.
7. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.