

c-84

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/GH/632

Dated 22/07/2022

To,

The Manager,
K87 Orchid Garden 51/1,
Prabhat Road, D.B.G. Road,
Karol Bagh, New Delhi.

Sub: Regarding renewal of FSC in r/o K87 Orchid Garden at 51/1, Prabhat Road, D.B.G. Road, Karol Bagh, New Delhi ID No. 2022033104771 dated 31.03.2022.

Sir,

This has reference to your letter no. Ho/9 dated 27/06/22 on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 21.07.22 in presence of Mr. Kamal and observed that the fire check doors on the staircase are not installed as per gazette notification 27.05.2019. Affidavit regarding not to use any floor above 3rd floor also to be submitted.

Therefore, you are requested to submit the compliance as per gazette notification 27.05.2019 for further consideration in the matter.

Yours faithfully,


29/07/22

(S.K.Dua)

Dy. Chief Fire Officer
Delhi Fire Service

✓

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.