

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2022/SZ/ 450
To

Dated: 4/8/2022

The Authorized Signatory
Tamana Special School,
D-6, Vasant Vihar, New Delhi 110057

Sub: Regarding issuance of Fire Safety Certificate in r/o Tamana Special School, located at
D-6, Vasant Vihar, New Delhi 110057

Sir,

This has reference with letter no nil dated 19/02/2022 received through outdoor diary no 2024 dated 01/06/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned site was visited by the officers concerned of this department on 06.07.2022 in the presence of Mr. Ved Prakash (Care Taker) and observed that the said building comprised of Basement, ground plus one upper floor having height 7.65m upto terrace level. This being Educational Occupancy buildings less than of 9 mtr in height and having less than of ground plus two upper floors, does not falls under the purview of building specified under sub Rule 4 of Delhi Fire Service Rules, 2010. Hence, fire safety certificate is not required.

Fire fighting arrangements such as fire extinguishers, hose reel hose, down comers system, smoke detectors, manual call points, exit sign's, sprinkler system in basement, terrace tank capacity 10,000 ltrs and terrace level pump capacity 900 lpm found installed. The fire fighting arrangements were checked/ tested randomly and found functional at the time of visit.

Further, the management of school authority is hereby directed to maintain all the fire fighting arrangements provided therein the building and these shall be in good working conditions at all the time as seen during visit. Any loss of life and property due to non functional of fire fighting measures shall be at the responsibilities of the management.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

du