



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आजादी का
अमृत महोत्सव

C12

No.F6/DFS/MS/School/SZ/2022/473

Dated: 10/08/2022

To

The Principal,
Vijay Bharti Public School,
D-53, Mohan Baba Nagar, Tajpur Road,
Badarpur, New Delhi-110044.

Sub:- Regarding renewal of Fire Safety Certificate in respect of Vijay Bharti Public School located at D-53, Mohan Baba Nagar, Tajpur Road, Badarpur New Delhi-110044.

Sir,

With reference to outdoor diary no. 3620 dated 21.07.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 29.07.2022 in the presence of Mrs. Harvinder Kaur and it was observed that the building which was earlier comprised of 2 block (G + 1 upper floor each) is now comprised of 2 block (Old block- G + 2 upper floors & New block G + 1 upper floors). 2nd floor in old block has been newly added to the existing building. Hence is a case addition/alteration. During the inspection following shortcomings were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters.
2. Alternate staircase having width not less than 0.75 mtrs must be provided from 1st floor to 2nd floor.
3. 05 nos. fire extinguishers provided against the requirement of 10 nos. fire extinguishers.
4. Hose reel not provided in old block.
5. Fire pump having capacity 450 LPM & head 40 mtrs. not provided old block.
6. Overhand tank capacity 10,000 ltrs not provided in old block for fire fighting.
7. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.