

C40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F6/DFS/MS/2022/School/ 459

Dated 4/8/2022

To

The Principal
Darshan Academy
Kirpal Bagh, Sant Kirpal Singh Marg,
Delhi-110009.

Sub: - Regarding issuance of fire safety certificate in r/o Darshan Academy, Kirpal Bagh, Sant Kirpal Singh Marg, Delhi-110009.


Sir,

This has reference to your letter no. DA/KB/E-3981/2022 dated 14.07.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 22.07.2022 to verify the fire safety measures installed in the building as per NBC- Part-4. During the course of inspection it was observed that the school premise is comprised of 02 blocks Ground plus 03 upper floors and ground floor only. At the time of inspection Mr. A. David (Principal) was also present at the site and the observations made are as under:-

1. Some hose reel nozzles found removed.
2. Internal hydrants some delivery hoses found missing & some branch found missing and damaged condition.
3. Terrace level fire pump capacity of 450lpm provided but auto system not functional at the time of inspection.
4. Terrace level fire water tank capacity of 5,000ltr found removed at terrace level and provided only 5,000ltr against the requirement of 10,000ltr for firefighting purpose.
5. Exit signage found missing at some places at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.