

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2022/NDZ/ 457

Dated: 4 / 8 / 2022

To

The Manager,  
Deep Bharti Public School,  
B-2/642, St. No.-26, Harsh Vihar, Delhi-110093.

**Sub.:- Inspection Report in r/o Deep Bharti Public School, B-2/642, St. No.-26, Harsh Vihar, Delhi-110093.**

Sir,

With reference to your letter No Nil dated 07/05/2022 & outdoor diary no. 2233 dated 07/06/2022 on the subject noted above, In this connection, it is to inform you that the said building premises was inspected by the officer concerned of this department on 25.07.2022 in the presence of Sh. Tarun Tyagi.


During the course of inspection it was observed that the building premises is comprised of Ground & 1st Floor Only (Earlier school was Ground Floor only).

**However, following shortcoming was observed during the time of inspection:-**

1. Two staircase of width 1.20 mtr & 1.10 mtr provided against requirement of 2 staircases of with 1.50 mtr each.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR.

Copy to :-

1. Director of Education, Old Secretariat, Civil Lines, Delhi-110054.

plc [Signature]