

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 452

Dated 4/8/22

To,

The Principal,
Nalanda Public School
A-3, Chajjupur Uttari, Shahdara, Delhi-110032.

Sub:- Regarding Issuance Fire Safety Certificate r/o Nalanda Public School located at A-3, Chajjupur Uttari, Shahdara, Delhi-110032.

Sir,

With reference to your letter nil dated 21/06/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 14/07/2022 of the above mentioned School from fire safety point of view in presence of the Principal of the school. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. First-Aid hose reels provided but not functional.
2. Fire pump on terrace having capacity 450 lpm output 40 meter found removed.
3. Over head water storage tank capacity 10,000 liters for firefighting found removed.
4. Exit signages found removed.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully



(S. K. DUA)

dlc Dy. Chief Fire Officer /
e. (NDZ)

Copy to:-

The Director of Education,
Old Secretariat
New Delhi-110054