

C22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/School/2022/ 453

Dated 7/8/2022

To

The Principal  
Sarvodaya Kanya Vidyalaya, Plot No. 5,  
A-Block, Jahangir Puri, Delhi-110033.


**Sub:** - Regarding issuance of fire safety certificate in r/o Sarvodaya Kanya Vidyalaya (School I'd No.1309279), Plot No. 5, A-Block, Jahangir Puri, Delhi-110033.

Sir,

Kindly refer to your letter No. SKV/P5/JP/417 dated 11.07.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 22.07.2022 to verify the fire safety measures issued vide NBC Part 4 and observed that the school premise is comprised of ground and 04 upper floors. At the time of inspection Sh. Dinesh (Guard) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Fire extinguisher provided in the building were checked and found not functional and short in no.
2. Hose reel hose provided but found not functional at the time of inspection.
3. MOEFA system provided but not functional.
4. PA system provided but not functional.
5. Internal hydrant provided but not functional and some hoses found missing.
6. Terrace level fire fighting pump capacity of 900lpm provided but not functional.
7. Terrace level fire water tank capacity of 25,000ltrs provided but found empty and domestic use.
8. Exit signage found removed at some places.

Yours faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:-011-23414250

Copy to: -

1. The Director of Education, Government of N.C.T of Delhi. Old Sectt. Delhi.