

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/ 463

DATED: 4 / 8 / 2022

To,

The Principal <dwarkasector22@gmail.com>  
School of Excellence,  
Sector – 22, Dwarka, New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o School of Excellence, (earlier known as Govt. Sr. Sec. School ) Located at Sector – 22, Dwarka, New Delhi (School ID – 1821282)

Sir,

Please refer to your letter no SOE/Sec-22/Dwk/2022/208, dated 02/07/2022 & Email Dated 04/07/2022 on the subject cited above. In this connection it is to inform you that the above said building has been visited by the officer concerned of this department t on 20/07/2022 in the presence of Dr. Ritu Kumari (HOS).


During the course of inspection followings shortcoming are observed

1. Hose reel hose found nonfunctional
2. Terrace pumps of 450 lpm found nonfunctional and not in auto mode
3. Exit signage's found removed at some places.

In view of the above, Fire Safety Certificate cannot be considered at this stage.

You are advised to rectify the said shortcomings under intimation to this department

Yours faithfully,



(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

