



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/11  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/SZ/2022/ 40

Dated: 10/8/22

To

Dr. Rashmi Panwar (Campus Director),  
World Class Skill Development Centre,  
Meerabai Institute of Technology,  
Maharani Bagh Campus, New Delhi.

Sub:- Regarding issuance of Fire Safety Certificate in r/o World Class Skill Development Centre, Meerabai Institute of Technology located at Maharani Bagh Campus, New Delhi.

Sir,

With reference to your letter no. F1/MBIT/Electrical Maintenance/2018-19/1882 dated 18.07.2022 on the subject cited above, it is informed that the procedure as suggested in letter no. F6/DFS/MS/SZ/2018/3919 dated 14.09.2018 (Copy enclosed) has not been followed as yet and following deficiencies were observed in your application for issuance of NOC/FSC.

1. Certificate of registered architect & owner is not attached with the application.
2. Sanction plans of the building are not attached with the application.

You are once again requested to reapply along with the afore stated documents.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

etc 04/8

Copy to:-

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.