

C17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2022/School/ 475

Dated: 11/08/2022

To,


The Principal,
Nigam Pratibha Kanya Vidyalaya-I,
Mubarak Pur Dabas,
Delhi-110086,

Sub: Issuance of Fire Safety Certificate in r/o Nigam Pratibha Kanya Vidyalaya-I, Mubarak Pur Dabas, Delhi-110086,

Sir,

Kindly reference to online mail dated 08.06.2022, received in this department on the subject cited above. In this connection submitted the building was visited by officer on dated 01.08.2022 however, it has been observed that the shortcoming already issued by this department letter of even No. 497 dated 21.02.2017 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings already issued vide this department letter dated 21.02.2017 for further consideration in this matter.

Yours Faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

etc
any

C/10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. *86/015/ans/school/2017/497*

Dated: *21/02* /2017

To

The Principal,
Nigam Pratibha Kanya Vidyalaya,
Mubarik Pur-I, Delhi-110086

Sub: - Regarding Fire safety Certificate Nigam Pratibha Kanya Vidyalaya, Mubarik Pur-I, Delhi-110086.

Sir,

Please refer to your letter No- nil dated 20/12/2016 on the subject noted above. In this connection, this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with **Sh. Anupam Singh (Principal)** on **01/02/2017** from fire safety point of view and following shortcomings were observed:

1. Seven fire extinguishers provided against the requirement of 12 fire extinguishers.
2. First aid Hose reel not provided.
3. Terrace pump of 450 LPM not provided.
4. Overhead water storage tank of 10,000 ltr not provided.
5. Exit signage not provided.

Keeping in view of above fire safety certificate cannot be considered at this stage.

Yours faithfully

(Signature)
(Atul Garg)

Chief Fire Officer
Ph: 011-23414250

8/2/17