

05

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/NDZ/2022/ 644

Dated: 5/8 /2022

To

The Manager,  
All time residency guest house,  
1658 to 1660 Plot no. 5, Khasra no. 561-3,  
Pahar Ganj, New Delhi.

Subject:- **Regarding issuance of FSC in r/o M/s All time residency guest house located at 1658 to 1660 plot no. 5 khasra no. 561-3 Pahar Ganj , New Delhi. ID No. 2022062913705 dated 07.07.22**

Sir,

This has a reference to online application ID No. 2022062913705 dated 07.07.22 on the subject cited above. In this connection, it is to inform you that the site was visited on dated 20.07.22 by the officers concerned of this department and following shortcomings are observed.

1. Fire check door not provided at basement.
2. Hose reel hose provided but found nonfunctional.
3. Smoke management system not provided in basement.
4. Fire Pump found non functional.
5. Lift signages are not provided.
6. The building plan does not have signature of owner /occupier himself .
7. Width of street as per PSS area on which the said guest house is situated is required.

In view of above, the Fire safety certificate cannot be issued. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

  
(Atul Gang)  
**DIRECTOR**  
Delhi Fire Officer

Copy to :-

The Jt. Commissioner of police ( Lic) Ist Floor , Defense colony police station , New Delhi.