

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2022/ 2058

Dated:

12/08/2022

To,

Sh. D.Sarkar,(Commissioner cum Secretary),
Delhi Development Authority,
Office of Commissioner Cum Secretary,
B-Block, 4th floor, Vikas Sadan, INA,
Delhi.

Sub:Issue of FSC in r/o DDA Zonal Office building at Madhuban Chowk, Rohini, Delhi.

Sir,

Kindly reference to OD No.1693 dated 23.05.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **13.07.2022**, in presence of **Sh. Ajay Vats (Ex Engg. Elect.)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Staircases are found not ventilated.
2. FCD auto closer not working & stopper/latches found provided.
3. MCP switch found removed at some at some places.
4. Electrical shaft not sealed at all floor levels.
5. Wooden room partition found created at some places.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully

(Atal Garg)
Director

Tel:-01123414000

d/c
12/8/22