



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2022/WZ/ CGHS/2057

Dated: 12/8/2022

To,

Mr. Prabhu Dayal Bathla,
Vasundhara Co-operative Group housing Society Ltd.
Plot No.44, Sector-IX, Rohini,
Delhi-85.

Sub: Issue of FSC in r/o Vasundhara Co-operative Group housing Society Ltd. Plot No.44, Sector-IX, Rohini, Delhi-85.

Sir,


Kindly reference to online e-mail dated 25.05.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **14.07.2022**, in presence of **Sh. Anand Kumar (Care-Taker)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for issue of FSC is rejected under sub rule (4) of Rule 35 of DFS Rules-2010 due to following reason:

1. Terrace Pumps were not in auto mode and gland packing of pump found leak.
2. Couplings of down comer found missing at many places.
3. MCP found not operational.
4. Exit signs found removed.
5. Hose-reel found missing at some places.
6. Hoses in hose box are in damaged condition.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

o/c

12/8/2022