



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2022/ 490

Dated:- 23 /08/2022

To

The Manager,
Inder Public School,
150, Village Mandawali Fazalpur,
Delhi-110092.

Sub: Regarding Renewal of FSC in r/o Inder Public School, 150, Village Mandawali Fazalpur, Delhi-110092.

Sir,

This has reference to your letter no. 510/2022 dated 21/07/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 05/08/2022 in the presence of Mr. Rajender Kumar (Manager) and observed that earlier school was Ground + 02 upper floors but now the school building is comprised of Ground + 03 upper floors. Therefore this is a case of additional/alteration and needs to route your application through bldg. deptt. of MCD.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

The Director (Education),
D-Block, Anand Vihar, Delhi - 91.