



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/WZ/2022/ 537

Dated: 23/8/22

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub:- Inspection report in respect of M/s. Aman Deluxe, A- 30, Vishal Enclave, Rajouri Garden, New Delhi- 110027.

Sir,

Please refer to your online application through MHA portal vide I.D. No. 2022071614698 dated 16/07/2022 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 04/08/2022 in presence of Sh. Amandeep Mahindru to check the shortcomings already issued by this department vide letter no. F.6/DFS/MS/GH/2022/WZ/399 dated 30.05.2022.

The Status of the Shortcoming is as under.

S. no.	Shortcomings	Status
1.	Fire Check Door Found removed in Basement.	Not Rectified
2.	First Aid Hose reels are provided but not working.	Rectified
3.	Carbon Monoxide (CO) detector is not provided.	Not Rectified
4.	Location of Main Panel at Ground Floor is not provided.	Not Rectified
5.	Hooters Location at all floors are not provided.	Not Rectified
6.	MOEFA is provided but not working.	Rectified
7.	Automatic sprinkler system is provided in Basement but not Functional.	Not Rectified
8.	Terrace pump of 450 LPM & 180 LPM is provided but not functional & not on auto mode.	Not Rectified
9.	Overhead water storage tank 2000 ltr provided against requirement of 5000ltr.	Rectified
10.	Exit signage's are found removed.	Rectified

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To :-

1. The Owner/Occupier M/s. Aman Dx, Guest House, A- 30, Vishal Enclave, Rajouri Garden New Delhi-110027.
2. The Dy. Health Officer, West Zone, Shivaji Enclave, Rajouri Garden, New Delhi-110027. (dhowest_zone@gmail.com)