

6-31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/School/WZ/2022/487

Dated: 23/8/22

To,

The Principal
Adarsh Shiv Shakti Shiksha Samiti (Regd.),
64, Chanderlok Enclave, Pitampura,
New Delhi - 110034.

Subject: Regarding Renewal of Fire Safety Certificate in r/o Adarsh Shiv Shakti Shiksha Samiti (Regd.) Located at 64, Chanderlok Enclave, Pitampura, Delhi - 110034.

Sir,


This is in reference to your letter received through outdoor diary on dated 14/06/2022, on the subject cited above. In this connection, it is to inform you that the School Building was inspected by the officer concerned of this department on 02/08/2022 in the presence of Mr. Jatinder Duggal to check the workability of fire safety arrangements provided in the building.

During Inspection it has been observed that the above School is comprised of Basement + Stilt + Ground + 02 upper floors + Tin Shed at Terrace. Fire safety arrangements Such as First Extinguisher, Smoke Management System, First-Aid Hose Reel, Pumping Arrangements, overhead water storage tank & Exit Signage etc are provided. However the following Shortcomings were observed.

1. First Aid-Hose Reels are provided not functional.
2. Terrace level pump are provided but not on auto mode.
3. Exit Signage found removed at some places.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To: -

1. The Directorate of Education old Secretariat, Delhi-110054.

dc 211
16/8/22