



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2022/SZ/EH/527

Dated 12/08/2022

To

The Dy. Health Officer, South Zone,  
Public Health Department,  
Aurobindo Marg, South MCD,  
Green Park, Delhi- 110016

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Mc Donald's Family Restaurant, (unit of Ms Connaught plaza Restaurant Pvt Ltd) at Shop No 34, 102B, 109, 110, GF & FF in MLCP DLF South Square Mall, Sarojini Nagar, New Delhi-110023.

Sir,

This has reference to your MHA Portal ID 2022071414580 dated 14/07/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01.08.2022 in the presence of Ms. Divya (B.M) to ascertain the availability and operability of fire protection and fire safety measures as installed in the building. During the course of inspection, the following shortcomings/ observations were noticed:

1. The width of rear side exit is now available 1.0 mtr wide by fixing of display table/rack in the way of exit. It shall be of 1.50 mtr wide as per the UBBL- 2016 requirements.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

**(SUNIL CHAWDHARY)**  
**DY. CHIEF FIRE OFFICER (SZ)**

Copy to:

1. The Authorized Signature, M/s Mc Donald's Family Restaurant, (unit of Ms Connaught plaza Restaurant Pvt Ltd) at Shop No 34, 102B, 109, 110, GF & FF in MLCP DLF South Square Mall, Sarojini Nagar, New Delhi-110023