

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/

483

Dated 23/8/22

To,

The Principal,  
Babu Ram Govt. Sarvodaya Bal Vidyalaya  
Bhola Nath Nagar, Shahdara,  
Delhi-110032.

Sub:- Regarding Issuance Fire Safety Certificate r/o Babu Ram Govt. Sarvodaya Bal Vidyalaya located at Bhola Nath Nagar, Shahdara, Delhi-110032.

Sir,

With reference to your letter No. BR/SBV/1733 dated 12/07/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Principal. The following points/shortcomings were noticed in the building which is comprised of ground plus three upper floors & ground plus one upper floor.

1. One Staircase of width 1.40 meter is provided in ground plus one upper floor, <sup>block.</sup> An additional staircase of 0.75 meter width is required in ground plus one upper floor.
2. First-Aid hose reel provided but not functional.
3. Terrace fire pump having 450 LPM output at 40 meter head not provided.
4. Overhead water storage tank capacity 10,000 liters is not provided.
5. Exit signage not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully

  
(S. K. DUA)

 DY. CHIEF FIRE OFFICER/(NDZ)

Copy to:-

The Director of Education,  
Old Secretariat  
New Delhi-110054