

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2022/ 642

Dated: 5.8/2022

To

The Manager,
B.B Place Guest House,
2638-42, Gurudwara Road,
Karol Bagh, New Delhi.

Subject:- **Regarding issuance of FSC in** r/o B.B Place Guest House, located at 2638-42, Gurudwara Road, **Karol Bagh, New Delhi..** ID No. 20220611126021 dated 11.07.22.

Sir,

This has reference to on line ID No. 20220611126021 dated 11.07.22 on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 27.07.22 in presence of Manager and found following shortcomings:-

1. Fire check doors are not provided
2. Hose reel provided but found nonfunctional.
3. ^{Fire} Pump found non functional.
4. The building plans as uploaded on the portal does not have signature of architect and owner.

In view of above, the Fire safety certificate cannot be issued. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

(Signature)
02/08/22

(S.K Dua)

Dy. Chief Fire Officer
Delhi Fire Officer

Copy to :-

1. The Jt. Commissioner of police (Lic) Ist Floor , Defense colony police station , New Delhi