

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2022/NDZ/ 508

Dated 24/08/2022

To,

The Vice Principal,
DAV Sr. Sec. School No. 1,
Gandhi Nagar, Delhi-110031.

Sub:- Regarding Issuance Fire Safety Certificate r/o DAV Sr. Sec. School No. 1, located at Gandhi Nagar, Delhi-110031.

Sir,

This is in reference to your letter No. DAV/1/22-23/90 dated 25/06/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Sh. S. K. Vatta, HOS of the School. The building comprised of ground (A-Block) & ground plus one upper floor (B-Block). Following shortcomings were observed during the time of inspection.

1. The premises is not accessible to fire engines.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully


(ATUL GARG)
DIRECTOR

o/c
e.
DELHI FIRE SERVICE

Copy to:-

The Director of Education,
Old Secretariat
New Delhi-110054