

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No.F6/DFS/MS/EH/NDZ/2022/ 648

Dated:- 5.7.2022

To

The Manager,
M/S Delhi Maharastryia Samaj Building Trust (Regd,),
At 10085, Multani Dhanda , Pahar Ganj, New Delhi.

Sub: Regarding grant of FSC in r/o M/S Delhi Maharastryia Samaj building trust (Regd), 10085, Multani Dhanda, Pahar Ganj, New Delhi. Id no. 2022065513501 dated 02.07.2022.

Sir,

This has a reference to online ID No. 2022065513501 dated 02.07.2022, on the subject cited above. It is to inform you that the site was visited by the officer concerned of this department on dated 26.07.22 in presence of Mr. Keshav and following shortcomings were observed: -

- 1) Fire check door at staircase at each floor and CO detectors are not provided as per gazette notification 27.05.2019.
- 2) Hose reel found non functional.
- 3) Fire extinguisher are due for refilling.
- 4) Terrace fire pump found non functional.
- 5) Terrace fire pump is also not provided with auto start provision.
- 6) No. of rooms as mentioned in application form are not matching with the rooms available in the guest house, required to be clarified the same.
- 7) Building plans as uploaded is not legible.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcoming at the earliest for further consideration in the matter.

Yours faithfully



(S. K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police
Station, New Delhi.