



7.2 C 48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 481

Dated: 18/08/2022

To,

The Principal,
Doon Public School,
B-2, Paschim Vihar,
New Delhi-110063.

Subject: Regarding Renewal of Fire Safety Certificate in r/o M/s Doon Public School, Located at, B-2 Paschim Vihar, New Delhi-110063.

Sir,


Please refer to your letter no. M-4736/DFS/2022 dated 29/06/2022 received in this office vide outdoor dairy No. 2881 dated 30.06.2022 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 02/08/2022 in presence of Sh. Sharat Chandran (Manager) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ/2022/136 dated 25/03/2022.

The Following Shortcomings Status is:-

S. no.	Shortcomings	Status
1.	First-Aid Hose Reels are provided but not functional.	Not Rectified
2.	Terrace fire pump of capacity 450 LPM is provided but not functional.	Not Rectified
3.	Over head water Storage tank capacity of 10,000 ltrs is provided but used as domestic purposes.	Rectified
4.	Exit signages are not provided.	Rectified

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.

dc
12/8/22