

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

69/75  
आज़ादी का  
अमृत महोत्सव

No.F6/DFS/MS/NDZ/2022/4H/666

Dated:-08/08/2022

To

The Manager  
M /S Elegance Guest House,  
7885/34, Arakashan Road,  
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Elegance Guest House located at, 7885/34, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. 2022071614691 dated 16.07.2022, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officers concerned of this department on 26/07/2022 in the presence of **Manager** and following shortcomings were observed:-

1. The main staircase is constructed by wood which is not allowed as per gazette notification dated 27.05.2019.
2. The building is comprised of ground and four upper whereas fourth floor building plan is not submitted.
3. Building plan is not signed by the owner/architect.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

*(Signature)*  
08/08/22

(S.K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Officer

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi