

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2022/

496

Dated: 23/08/2022

To

The Principal,  
Florence Public School,  
19-A, Pratap Nagar, Mayur Vihar Ph-1,  
Delhi-110091.

**Sub: Regarding Fire Safety Certificate in r/o Florence Public School located at 19-A,  
Pratap Nagar, Mayur Vihar Ph-1, Delhi-110091.**

Sir,

This has reference to your letter no. nil dated 29/07/2022 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 03/08/2022 in the presence of Mrs. Rajani (Teacher) & Ms. Kiran (Teacher) and observed that earlier FSC was issued to school bldg. comprised of Ground + 02 upper floors only but now the school building is comprised of Ground + 03 upper floors. Therefore this is a case of additional/alteration and needs to route your application through bldg. deptt. of MCD. Further the fire fighting system provided is not functional.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

The Director (Education),  
Govt. of NCT, Old Sectt.  
Delhi - 54.

ok  
MD