

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

**No: F.6/DFS/MS/School/2022/SZ/**

499

**Dated: 23/8/22**

To,

The Principal,  
Govt. Girls Senior Secondary School No.-2,  
Najafgarh, New Delhi-110043

**Sub: -** Regarding issuance of Fire Safety Certificate in r/o. Govt. Girls Senior Secondary School No.-  
2, Najafgarh, New Delhi-110043.

Sir,

This has reference to your Letter No. GGSSS No2/NJF/191 dated 06/07/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 27/07/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Mr. Jeet Singh (Estate Manager) was present and it was observed that the school building is comprised of ground plus three upper floors and have following shortcomings.

1. First aid hose reels provided but not functional.
2. Fire pump having 450 lpm provided but not functional at terrace.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Sunil Chawdhary)

Dy. Chief Fire Officer

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.