



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No. F.6 DFS/MS/EH/2022/NDZ/ 511

Dated: 03/08/2022

To,

The Manager  
Honey & Dough (Eating House)  
Plot No. 115, Hargovind Enclave,  
Delhi-110092

**Sub:-** Regarding Issuance of Fire Safety Certificate in r/o M/s Honey & Dough (Eating House) located Plot No. 115, Hargovind Enclave, Delhi-110092.

Sir,

With reference to your online MHA application No. 2022070413963 dated 04/07/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the premises from fire safety point of view in presence of Sh. Aarav, Manager on dated 20/07/2022. The building comprised of ground plus three upper floors. Following shortcomings were observed during the time of inspection:-

1. One door of width 0.90 meter provided against requirement of two doors of width 1.50 meter each.
2. First Aid Hose reel not provided.
3. MOEFA is not provided.
4. Down Comer not provided.
5. A fire pump having capacity of 900 lpm output of 40 meter head at terrace not provided.
6. Over head tank having of capacity 20,000 liters not provided.
7. Exit signage not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

o/c.  
2

Copy to:-

The Joint Commissioner (Lic.)  
1<sup>st</sup> floor Police Station Defence Colony, New Delhi