

c-17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/DFS/MS/EH/2022/ 515
To

Dated 04/08/2022

The Manager,
Shop No. 85 & 87, Ground Floor, Mall Road,
GTB Nagar, Kingsway Camp, Delhi-110009.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Jubilant Food Works Limited Dominos Pizza located at Shop No. 85 & 87, Ground Floor Mall Road, GTB Nagar, Kingsway Camp, Delhi-110009.

Sir,

This has reference to your online mha portal I.d No. 2022063013807 dated 04.07.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 20.07.2022 in the presence of Sh. Deviram (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it is observed that the building/ premise is comprised of basement, ground & 02 upper floors (Restaurant running at ground floor only). Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 There are two exit doors having width of 01m & 90cm provided against requirements of 1.50m each. The second exit is also not qualifying the requirement of safe means of escape as this exit route is through the kitchen area of the restaurant.
- 2 First aid hose reel hose not provided.
- 3 Internal hydrants with hose box is not provided.
- 4 Terrace level fire pumps capacity of 450lpm not provided.
- 5 Terrace level fire water tank capacity of 20,000ltrs not provided.
- 6 Exit signage's not provided in the restaurant.
- 7 Standby power supply not provided.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.

Yours faithfully


(Atul Garg)
Director
Ph: 011-23414000

07/08/22

Copy to:

1. The Dy. Health Officer, Civil Line Zone, 16, Rajpura Road, Delhi-110054.
2. The Additional Commissioner of Police/Lic, 1st Floor, PS Defence Colony, New Delhi.