

C-38

C-38

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F6/DFS/MS/School/2022/NDZ/

489

Dated 23/8/22

To,

The Principal,
Lovely Public Middle School,
5, Old Geeta Colony,
Delhi-110031

Subject:- Regarding renewal of Fire Safety Certificate in r/o Lovely Public Middle School
located at 5, Old Geeta Colony, Delhi-110031.


Sir,

With reference to your letter No. LPMS/GC/2022-232/C-1 dated 05/07/2022 on the subject cited above, In this connection, this is to inform you that the re-inspection of the above said premises was carried out by the officer concerned of this department on dated 04/08/2022 in presence of Sh. Vipin Sharma. During the inspection, it was observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/School/2022/NDZ/65 dated 11/02/2022 (Copy enclosed) have not been complied yet.

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours faithfully

Encl:- As above



(S. K. DUA)

DY. CHIEF FIRE OFFICER/(NDZ)

R. o/c

Copy to:-

The Joint Director of Education (Land & Estate),
Directorate of Education,
Lucknow Road, Delhi-110054

c/29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/NDZI/ 65

Dated: 11/02/2022

To,

The Principal,
Lovely Public Middle School,
5, Old Geeta Colony,
Delhi-110031

Subject:- Renewal of Fire Safety Certificate.

Sir,

With reference to email ID lpsjupiter@yahoo.co.in dated 12/11/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Sunita Dhingra (A.M.) on dated 14/01/2022. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-

1. An overhead water tank having 2,000 liters capacity is provided against the required capacity of 10,000 liters.
2. Firefighting systems (fire pump & hose reel) which have been provided in the building, was not functional.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

O/c 

Copy to:-

The Joint Director of Education (Land & Estate),
Directorate of Education,
Lucknow Road, Delhi-110054