

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/2022/ 505

Dated: 24/08/2022

To

The Principal,
M.C.G. Primary School,
Gali Babbu Khan-1, Ballimaran, Delhi- 06.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o
M.C.G. Primary School, Gali Babbu Khan-1, Ballimaran, Delhi- 06.**


Sir,

Please refer to your letter no. nil dated 28.07.2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school premises on 12.08.2022 to verify the fire safety arrangements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education. At the time of inspection Mohd. Nasir (Principal), was present and it was observed that the school building is comprised of ground plus three upper floors and school running at ground + 01 upper floor and have complied the shortcomings issued vide letter no. F.6/DFS/MS/School/2014/266 dated 31.01.2014 except following which still exists:-

1. Additional staircase having width of not less than 0.75 m is required.

In view of above, the fire safety certificate cannot be issued. You are suggested to rectify the above said shortcoming under the intimation to this department for further course of action. Running school without valid Fire Safety Certificate is at the risk and liability of school management. Concerned authority may take action at their end.

Yours faithfully,


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

01
8
23/8

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi