



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2022/NDZ/ 503

Dated: 24/08/2022

To

The Manager,  
M.N.B. Modern Secondary School,  
Ph-09, Gali No.- 01, Shanti Nagar Gate,  
Shiv Vihar, Delhi-110094.

**Sub.- Inspection Report in r/o M.N.B. Modern Secondary School, Ph-09, Gali No.- 01, Shanti Nagar Gate, Shiv Vihar, Delhi-110094.**

Sir,

With reference to your Letter No. MNB/Fire/2022 Dated Nil on the subject noted above. In this connection, it is to inform you that the said building premises was inspected by the officer concerned of this department on 08.08.2022 in the presence of Sh. Manoj Sharma and observed that the building premises is **now comprised of Ground, 1<sup>st</sup> floor, 2<sup>nd</sup> floor & 3<sup>rd</sup> floor. Earlier it was Ground and Two upper floor only.** This is a case of Addition/Alteration.

In view of above, the application for issuance Fire Safety Certificate is rejected. You are requested to forward complete set of building plan including section/elevation/layout plan of current occupancy in the scale of 1:100 as mentioned in UBBL-2016 duly marked with fire and life safety measures as per NBC part-IV/As built plan for taking necessary action in this matter.

The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. Statutory authority may take action as deemed fit at their end please.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR

o/c d/s

Copy for information :-

1. Director of Education, Old Secretariat, Civil Lines, Delhi-110054.