

028



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/ ~~EH/SZ/2021~~ / 508

DATED: 02/08/2022

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire Safety Certificate in r/o Munde Distributors LLP (Restaurant) Located at Ground floor, RSM02, Plot No. 1, Sector – 13, Dwarka, New Delhi.

Sir,

This is in reference to online application No. 2022042508261, dated-14/06/2022 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 04/07/2022 in the presence of Sh. Manoj (Manager)

During the course of inspection followings shortcoming have been observed:-

1. Exit found not clear/ partially obstructed..
2. Hose reel must reach at the last end of the restaurant.
3. Exit signage found removed.
4. MOEFA provided for the restaurant found nonfunctional.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

Sh. Manoj (Manager) Munde Distributors LLP (Restaurant) Located at Ground floor, RSM02, Plot No. 1, Sector – 13, Dwarka, New Delhi

10 o/c
15/8